

# REPORT ALL

# OIL AND HAZARDOUS SUBSTANCE SPILLS

**ALASKA LAW REQUIRES REPORTING OF ALL SPILLS**

**During normal business hours**

contact the nearest DEC Area Response Team office:

## Central Alaska

**Anchorage phone: (907) 269-3063**

**fax: (907) 269-7648**

## Northern Alaska

**Fairbanks phone: (907) 451-2121**

**fax: (907) 451-2362**


## Southeast Alaska

**Juneau phone: (907) 465-5340**

**fax: (907) 465-2237**

**Outside normal business hours, call:**

**1-800-478-9300 (International 1-907-428-7200)**



---

**Alaska Department of Environmental Conservation**  
Division of Spill Prevention and Response

# Discharge Notification and Reporting Requirements

AS 46.03.755 and 18 AAC 75 Article 3

Notification of a discharge must be made to the nearest Area Response Team during working hours:

Anchorage (907) 269-3063

Fairbanks (907) 451-2121

Juneau (907) 465-5340

(907) 269-7648 (FAX)

(907) 451-2362 (FAX)

(907) 465-2237 (FAX)

OR

to the 24-Hour Emergency Reporting Number during non-working hours:

1-800-478-9300 (International 1-907-428-7200)

## Notification Requirements

### Hazardous Substance Discharges

Any release of a hazardous substance must be reported as soon as the person has knowledge of the discharge.

### Oil Discharges

#### ■ TO WATER

- Any release of oil to water must be reported as soon as the person has knowledge of the discharge.

#### ■ TO LAND

- Any release of oil in **excess of 55 gallons** must be reported as soon as the person has knowledge of the discharge.
- Any release of oil in **excess of 10 gallons, but 55 gallons or less**, must be reported within 48 hours after the person has knowledge of the discharge.
- A person in charge of a facility or operation shall maintain, and provide to the Department on a monthly basis, a written record of any discharge of oil **from 1 to 10 gallons**.

#### ■ TO IMPERMEABLE SECONDARY CONTAINMENT AREAS

- Any release of oil **in excess of 55 gallons** must be reported within 48 hours after the person has knowledge of the discharge.

## Special Requirements for Regulated Underground Storage Tank (UST) Facilities\*

If your release detection system indicates a possible discharge, or if you notice unusual operating conditions that might indicate a release, you must notify the Storage Tank Program at the nearest DEC Office within 7 days:

Anchorage (907) 269-7886

(907) 269-7679

\*Regulated UST facilities are defined at 18 AAC 78.005 and do not include heating oil tanks.